

CONCEPT BOILER SYSTEMS

BOILER SHUTDOWN PROCEDURE

1. Open the Blowdown Valve located at the bottom left side of boiler for approximately 5 seconds, or until feedwater pump starts and stops, then close the valve.
2. Blowdown all Gauge Glass mounts independently as instructed.
3. Turn the FILL/OFF/RUN switch to the OFF position.
4. Leave the Main Steam Valve open (Optional).
5. Turn the Main Isolation switch located on left side of control panel to the OFF position.
6. Close the Main Gas Valve to boiler if boiler to be off for a long period of time.
7. Close the Feedwater Isolation Valve located between the tank and boiler.
8. The boiler is now "Off line" and isolated.

SEARCH **CONCEPT BOILER SYSTEMS** OR CALL **0408 367 913** FOR SERVICE

